

**2020 Water Audit**  
Certified Validation Report



**Part A: Provided by Validator**

**Audit Information:**

Utility: City of Compton PWS ID: 1910026  
System Type: Potable Audit Period: Fiscal 2017 Utility Representation: Brian Dickinson  
Validation Call Date: 5/20/2020

**Validation Findings & Confirmation Statement:**

**Key Audit Metrics:**

Data Validity Score: 47 Data Validity Band (Level): Band II (31-50)  
ILI: 0.54 Real Loss: 7.32 (gal/conn/day) Apparent Loss: 12.55 (gal/conn/day)

**Certification Statement by Validator:**

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34. All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

**Validator Information:**

Water Audit Validator: Greg Ripperger Validator Qualifications: Water Audit Validator Certificate

**Part B: Provided by Utility**

Water Supplier Name: City of Compton Water Supplier ID Number: 1910026 Water Audit Period: Fiscal 2017

**Water Audit & Water Loss Improvement Steps:**

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss, as informed by the annual validated water audit:  
Begin testing well meters and provide results of tests.

**Certification Statement by Utility Executive:**

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software.

Executive Name (Print):

Brian A. Dickinson

Executive Position:

General Manager

Signature:

Brian A. Dickinson

Date:

6/9/2020